



Smoke Alarms and Carbon Monoxide Alarms

Residential Certification of Installation

INFORMATION
GUIDELINE

January 2020

City of Pleasant Hill • Building Division • 100 Gregory Lane • Pleasant Hill, CA 94523 • (925) 671-5200 • Fax (925) 676-1125

The State of California requires that smoke alarms and carbon monoxide alarms must be installed in all residential buildings. The 2019 California Residential Code (CRC) Section R314 and CRC R315 state in part that existing dwellings be retrofitted with smoke alarms and carbon monoxide alarms “when a building permit is issued for alterations, repairs or additions to a dwelling.”

Alarms must be installed and maintained in the following specified locations:

Carbon Monoxide Alarms: On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of bedrooms and on each story of the dwelling.

Smoke Alarms: Installed in each room used for sleeping purposes, outside each sleeping area in the immediate vicinity of bedrooms, and on each story of the dwelling unit.

Retrofitted alarms may be battery operated for buildings where no alterations are performed on the interior or interior alterations do not result in the removal of wall or ceiling finishes. All alarms shall comply with all applicable standards and must be approved by the California State Fire Marshal. All alarm devices must be installed and maintained in accordance with the CA Residential Code and the manufacturer’s instructions.

NOTE: This self-certification option is only available for alterations, repairs or additions to the exterior of the structure where access to the interior of the dwelling by the City of Pleasant Hill Building Inspector is not achieved during the course of construction.

Project Address: _____

Permit Number: _____

Property Owner: _____

Licensed Contractor: _____ License No.: _____

I, the undersigned, hereby certify that I have verified that the smoke alarms and carbon monoxide alarms are installed and tested to be functional in all the above specified locations.

Owner Signature: _____

Contractor Signature: _____ Date: _____

On the back of this certification form are the general requirements for the installation of smoke alarms and carbon monoxide alarms for residential buildings based on the 2019 California Building Code, 2019 California Residential Code, and the 2019 California Fire Code.

The following information is intended to provide general information, contact the Building Safety Division for any questions or additional information.

New Construction and Additions

In new construction and additions, required smoke alarms and carbon monoxide alarms shall receive their primary power from the permanent building electrical power system (and shall be on the lighting circuit connected within the same room as the smoke alarm). Where two or more smoke alarms or carbon monoxide alarms are required they shall be interconnected in such a manner that actuation of one shall cause actuation of all detectors in the dwelling unit. (CBC 907.2.11, CRC R314, CRC R315)

All new electrical outlets (including smoke alarms, carbon monoxide alarms, receptacles, switches, lighting, etc.) shall be on circuits protected with a combination arc-fault circuit interrupter. (2019 CEC 210.12)

Remodeled Dwelling Units

When a permit is required for any repair, alterations, or addition smoke alarms and carbon monoxide alarms shall be installed in accordance with the following location and maintenance provisions. In existing dwelling units, smoke alarms and carbon monoxide may be battery operated. (CBC 907.2.11, CRC 314, CRC 315)

Rooms/Spaces that Require Smoke Alarms and Carbon Monoxide Alarms

Room/Space	Smoke Alarm Required? (CBC 907.2 and CRC 314)	Carbon Monoxide Alarm Required? (CBC 907.2 and CRC 315)
Outside of each separate sleeping area in the immediate vicinity of bedrooms (i.e. hallway)	Yes	Yes
In each sleeping room	Yes	No
In each story within a dwelling unit, including basements.	Yes	Yes
In enclosed common stairwells of apartment complexes and other multiple- dwelling complexes	Yes	No
In a group R-3.1 (i.e. adult residential facilities), in addition to the above, smoke alarms shall be provided throughout the habitable areas of the dwelling unit except kitchens	Yes	No

Smoke Alarm and Carbon Monoxide Alarm Device Location

Smoke alarms shall be installed on the ceiling or wall between 4” and 12” of the ceiling. Carbon monoxide alarms shall be installed on the ceiling or wall above the door header.

Maintenance

The owner shall be responsible for testing and maintaining detectors in hotels, motels, lodging houses, and common stairwells of apartment complexes and other multiple dwelling complexes. The smoke alarm shall be operable at the time that the tenant takes possession. The apartment complex tenant shall be responsible for notifying the manager or owner if the tenant becomes aware of an inoperable smoke alarm within his or her unit. The owner or authorized agent shall correct any reported deficiencies in the smoke alarm and shall not be in violation of this section for a deficient smoke alarm when he or she has not received notice of the deficiency. (CFC 907.9 and California Health and Safety Code 13113.7)

Smoke Alarm Batteries and Replacement

All newly installed smoke alarms shall have a 10-year battery. Smoke alarms shall be replaced 10 years from the date of manufacture marked on the unit. (CBC 907.2.11.2, CRC 314, CRC 315)